



TRUESDAIL LABORATORIES, INC.

# Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

Apollo Valves, Conbraco Industries, Inc.  
1418 S. Pearl Street  
Pageland, S.C. 29728

**Plant Location:**

Pageland, S.C.

**Standards:**

NSF/ANSI 61 Section 8 (2010)  
NSF/ANSI 61 Section 8 Annex F  
NSF/ANSI 61 Section 8 Annex G  
California Health & Safety Code §116875 [AB 1953 (2006)]  
Vermont Act 193  
Weighted Average Lead Content  $\leq 0.25\%$   
Federal Public Law 111-380  
Maryland Chapter 407  
NSF/ANSI 372

**Certificate Expires:**

12/31/2016

**Material/Product:**


33LF Series Bronze Globe Valves

**Contact Temperature:**

180  $\pm$  4°F

**Models:**

120T-LF (2" Bronze Globe Valve, PTFE Seat, NPT), 121T-LF (2" Bronze Globe Valve, Metal Seat, NPT), 120T-LF (33LF130 Series; 3/8"-2" Bronze Globe Valve, PTFE Seat, NPT), 120S-LF (33LF140 Series; 3/8"-2" Bronze Globe Valve, PTFE Seat, Solder), 121TLF (33LF160 Series; 3/8"-2" Bronze Globe Valve, Metal Seat, NPT)



See attached sheet for additional information and restrictions



ANSI Accredited Program  
PRODUCT CERTIFICATION  
ID #0303