



TRUESDAIL LABORATORIES, INC.

# Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

Global Eco Technologies, Inc.  
340 Cumberland St., Suite A  
Pittsburg, CA 94565

**Plant Location:**

Santa Fe Springs, CA

**Standards:**

NSF/ANSI 61 Section 5 (2009)

**Certificate Expires:**

12/31/2014

**Material/Product:**


Polyurethane Barrier Material

**Contact Temperature:**

23° C

**Models:**

Endura-Flex 1988 (off white), Endura-Flex 1988 (black), Endura-Flex 1988 (blue), Endura-Flex 1988 (red oxide), Endura-Flex 1988 (F-off white), Endura-Flex 1988 (F-black), Endura-Flex 1988 (F-blue), Endura-Flex 1988 (F-red oxide)



ANSI Accredited Program  
PRODUCT CERTIFICATION  
ID #0303

See attached sheet for additional information and restrictions



## ADDITIONAL INFORMATION

### COMPANY

Contact  
Phone

Global EcoTechnologies, Inc.  
P.O. Box 2205  
Antioch, CA 94531  
Technical Department

### PRODUCT DESCRIPTION

Product Brand Name/Model Number

Polyurethane Barrier Material  
Endura Flex

### MATERIAL CHARACTERISTIC

Minimum tank size (gallons) 700

Max Surface Area/Vol ratio (sq cm/L) 43

Colors

Number of coats <sup>(1)</sup> 1

Dry film thickness (mils) <sup>(1)</sup> 125

Recoat dry time/temperature 4 hrs @ 75 - 80° F

Total cure time/temperature 72 hrs @ 75 - 80° F

Mix Ratio (A:B) : 1:2 (by volume)

Flushing or preparation instruction  
prior to use

Flush with adequate amount of  
water. Please refer to manufacturer's  
instruction.

Comments

Please refer to manufacturer's  
instruction.

### CONTACT RESTRICTION

Contact Temperature (°F) 75 to 80

Contact Material Water

Note (1) As tested.