



TRUESDAIL LABORATORIES, INC.

# Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

Sika Services AG  
Speckstrasse 12  
Pfaffikon, Switzerland

**Plant Location:**

Santa Fe Springs, CA (Co-listed product from American Polymer Corp. (d.b.a) Polycoat Product)

**Standards:**

NSF/ANSI 61 Section 5 (2009)

**Certificate Expires:**

12/31/2014

**Material/Product:**


Polyurethane Barrier Material

**Contact Temperature:**

23° C

**Models:**

Sikalastic® - 841ST



ANSI Accredited Program  
PRODUCT CERTIFICATION  
ID #0303

See attached sheet for additional information and restrictions



## ADDITIONAL INFORMATION

### COMPANY

Sika Services AG

Contact  
Phone

Speckstrasse 12  
Pfaffikon, Switzerland  
Technical Department

### PRODUCT DESCRIPTION

Product Brand Name/Model Number

Polyurethane barrier material  
Sikalastic – 841ST

### MATERIAL CHARACTERISTIC

Minimum tank size (gallons) 500

Max Surface Area/Vol ratio (sq cm/L) 48

Colors

Number of coats <sup>(1)</sup> 1

Dry film thickness (mils) <sup>(1)</sup> 175

Recoat dry time/temperature

Total cure time/temperature

Mix Ratio

48 hrs @ Max 25° C

Please refer to manufacturer's  
instruction.

Flushing or preparation instruction  
prior to use

Flush with adequate amount of  
water. Please refer to manufacturer's  
instruction.

Comments

Please refer to manufacturer's  
instruction.

### CONTACT RESTRICTION

Contact Temperature (°F)

75 to 80

Contact Material

Water

Note (1) As tested.