



Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Alchemy Spetec, LLC
4508 Bibb Blvd
Suite B-5
Tucker, GA 30084, United States

Plant Location:

Tucker, GA, United States

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI/CAN 372 - 2022

Certificate:

Issued Date: 04/11/2024

Material/Product:

AP Fill 700 v. 3.0 - Single Component, Moisture Activated, Hydrophobic, Low Viscosity, Closed Cell Polyurethane Injection Resin

Contact Temperature:

23 ± 2°C

Models:

AP Fill 700 v. 3.0

Maximum surface area in contact with water shall not exceed more than 1% of the total surface area.



Material Characteristics:

Minimum tank size (gallons): 200

Maximum tank surface area/volume ratio (sq in/L): 10.5

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Final cure time: 3 days

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Maximum surface area in contact with water shall not exceed more than 1% of the total surface area.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.