

ALS Group USA, Corp.

3337 Michelson Drive, Suite CN750, Irvine, CA 92612

Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

Alchemy Spetec, LLC 4508 Bibb Blvd Suite B-5 Tucker, GA 30084, United States

Plant Location:

Tucker, GA, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 04/21/2021

Material/Product:

AP Lift 475 v. 3.0 - Two Component, High Strength, High Density, Hydro insensitive Structural Polyurethane Foam

Contact Temperature:

23 ± 2°C

Models:

AP Lift 475 v. 3.0

Maximum surface area in contact with water shall not exceed more than 10% of the total surface area.







3337 Michelson Drive, Suite CN750, Irvine, CA 92612

Material Characteristics:

Minimum tank size (gallons): 300

Maximum tank surface area/volume ratio (sq in/L): 9

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Final cure time: 3 days

Mix ratio: 1:1

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Maximum surface area in contact with water shall not exceed more than 10% of the total surface area.

