



Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Sika Corporation
201 Polito Ave
Lyndhurst, NJ 07071, United States

Plant Location:

Santa Fe Springs, CA, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 10/18/2021

Material/Product:

Potable Water Reservoirs, Tank Liners, Pond Liners, and Containment

Contact Temperature:

23 ± 2°C

Models:

Sikagard 7600 HG/VG



Material Characteristics:

Minimum tank size (gallons): 5000

Maximum tank surface area/volume ratio (sq in/L): 3.3

Maximum dry film thickness per coat (mils): 120 (3 mm)

Number of coats: 2

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 48 hrs at maximum of 23 Å°C

Mix ratio: 1:9 by Volume (A:B)

Is this paint/coating system intended to be applied to a pipe? (Y/N): No



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.