



Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Rhino Linings Corporation
9747 Businesspark Ave
San Diego, CA 92131, United States

Plant Location:

Greenville, TX, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 09/30/2021

Material/Product:

Spray Elastomer Coating

Contact Temperature:

23 ± 2°C

Models:

PipeLiner 5000 PW



Material Characteristics:

Minimum pipe diameter (inches): 10

Maximum pipe surface area/volume ratio (sq in/L): 24.4

Minimum tank size (gallons): 20,000

Maximum tank surface area/volume ratio (sq in/L): 2.1

Maximum dry film thickness per coat (mils): 250

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Refer to manufacturer instructions for details

Total cure time and temperature: Full cure 72 hours at 75 Å°F

Shortest cure time between coats or layers: Immediate

Mix ratio: 1:1 (A:B) by weight

Colors: Light Blue, White

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): No

Additional comments:

Primer can be used for additional coating if adhesion to intermediate coat, top coat, and the substrate is required. Primer 1500 is applied at 3-5 wet mils and lining can be applied at 20 to 250 mils per pass.

Application includes pipe refurbishment.