



## Certified Product Listing

**For:**

Drinking Water System Components - Health Effects

**Company:**

Zebron Corporation  
1141 N Cosby Way  
Unit H  
Anaheim, CA 92806, United States

**Plant Location:**

Anaheim, CA, United States

**Standards:**

NSF/ANSI 61 Section 5

**Certificate:**

Issued: 02/10/2017

**Material/Product:**

Polyurethane Protective Coatings

**Contact Temperature:**

23 ± 2°C

**Models:**

Zebron 386/9000



Product certified to NSF/ANSI 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



## Material Characteristics:

Minimum pipe diameter (inches): 48

Maximum pipe surface area/volume ratio (sq in/L): 5.1 (33 sq cm/L)

Minimum tank size (gallons): 4000

Maximum tank surface area/volume ratio (sq in/L): 3.57 (23 sq cm/L)

Maximum dry film thickness per coat (mils): 250

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Refer to manufacturer instructions for details

Total cure time and temperature: 5 days @ 23°C

Mix ratio: 3:1 (Zebron 386:Activator 9000) by Volume

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): No



Product certified to NSF/ANSI 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.