



## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

VersaFlex Incorporated  
686 S Adams Street  
Kansas City, Kansas 66105, United States

**Plant Location:**

Kansas City, KS, United States

**Standards:**

NSF/ANSI/CAN 61 - 2022

**Certificate:**

Issued Date: 03/07/2019

**Material/Product:**

Polyurea Interior/Lining Barrier System for Tanks, Vessels, Storage Containers and Pipes that are used for Potable/Drinking Water

**Contact Temperature:**

60 ± 2°C

**Models:**

AquaVers 20



## Material Characteristics:

Minimum pipe diameter (inches): 1.5

Maximum pipe surface area/volume ratio (sq in/L): 163

Minimum tank size (gallons): 600

Maximum tank surface area/volume ratio (sq in/L): 7

Maximum dry film thickness per coat (mils): 110

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Refer to manufacturer instructions for details

Total cure time and temperature: 45 minutes max at ambient temp

Mix ratio: 1:1 by Volume

Colors: Multiple

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.