



Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Prime Resins, Inc.
2291 Plunkett Road
Conyers, GA 30012-3433, United States

Plant Location:

Conyers, GA, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 10/27/2017

Material/Product:

Epoxy Coating

Contact Temperature:

23 ± 2°C

Models:

Prime Coat 4000



Material Characteristics:

Minimum tank size (gallons): 300

Maximum tank surface area/volume ratio (sq in/L): 9

Maximum dry film thickness per coat (mils): 77.56 (1.97 mm)

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 7 days at $23 \pm 2^\circ\text{C}$

Mix ratio: 1A:1B by volume

Colors: Grey

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Re-coat dry time/temperature: 36 hours / $23 \pm 2^\circ\text{C}$

Flushing or preparation instruction prior to use:

- a) Flushing Time: General Flush
- b) Estimate Flow Rate (gpm): 3
- c) Temperature of Flush: $23 \pm 2^\circ\text{C}$