



## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

Fu San Machinery Co. Ltd.  
22 Lane 89 Sec 4  
Chang-Mei Road  
Ho-Mei Town, Chang Hua, Taiwan, Province of China

**Plant Location:**

Chang Hua, Taiwan R.O.C.

**Standards:**

NSF/ANSI/CAN 61 - 2022

**Certificate:**

Issued Date: 11/26/2019

**Material/Product:**

Full Port Ball Valves

**Contact Temperature:**

23 ± 2°C

**Models:**

F1361FP  
F1361FPK  
F1361FPLD  
F1361FPLDSS  
F1361FPSS  
F1362FP  
F1362FPK  
F1362FPLD  
F1362FPLDSS  
F1362FPSS

This product is not suitable for use in the United States with potable water due to failure to meet NSF/ANSI 372 "Lead Free" requirement.