



## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

SealBoss Corporation  
1669 E Wilshire Avenue  
Santa Ana, CA 92705, United States

**Plant Location:**

Santa Fe Springs, CA, United States

**Standards:**

NSF/ANSI/CAN 61 - 2022

**Certificate:**

Issued Date: 04/15/2019

**Material/Product:**

SealBoss FlexGel System

**Contact Temperature:**

23 ± 2°C

**Models:**

SealBoss FlexGel System



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



## Material Characteristics:

Minimum tank size (gallons): 20,000

Maximum tank surface area/volume ratio (sq in/L): 2.1

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 5 min / 77  $\pm$  5  $^{\circ}$ F up to 24 hr / 77  $\pm$  5  $^{\circ}$ F

Mix ratio: 1:8 by weight (1:10 Max; SealBoss FlexGel : Water)

Colors: Original

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Maximum crack fill width (inch) on a normal run: 0.25

Flushing, preparation, or application instruction prior to use:

Normal flush for a minimum 15 seconds at approximately 3 gpm water at ambient temperature.

The surface area of the product that touches water should not exceed more than 0.1% coverage of the total surface area.