



## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

BASF Corporation  
1609 Biddle Avenue  
Wyandotte, MI 48192, United States

**Plant Location:**

Geismar, LA, USA

**Standards:**

NSF/ANSI/CAN 61 - 2022

**Certificate:**

Issued Date: 08/30/2016

**Material/Product:**

Polyurea Elastomer Coating

**Contact Temperature:**

23 ± 2°C

**Models:**

ELASTOCAST S 72285R Resin / 72280T Isocyanate



## Material Characteristics:

Minimum pipe diameter (inches): 1.5

Minimum tank size (gallons): 5

Maximum dry film thickness per coat (mils): 30

Number of coats: 3-4

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 48 hrs @ 23Â°C

Shortest cure time between coats or layers: 5-15 seconds @ 23Â°C

Mix ratio: 1:1 by volume

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Flushing or preparation instruction prior to use:

Flush with adequate amount of water. Please refer to manufacturerâ€™s instruction.