ALS Group USA, Corp.
3337 Michelson Drive, Suite CN750, Irvine, CA 92612

Certified Product Listing

For:
Drinking Water System Components – Health Effects

Company:
The Euclid Chemical Company
19218 Redwood Road
Cleveland, OH 44110, United States

Plant Location:
Euclid-1, United States

Standards:
NSF/ANSI/CAN 61 - 2022

Certificate:
Issued Date: 10/27/2017

Material/Product:
Epoxy Coating

Contact Temperature:
23 ± 2°C

Models:
Duralkote 61

Material Characteristics:

Minimum tank size (gallons): 300

Maximum tank surface area/volume ratio (sq in/L): 9

Maximum dry film thickness per coat (mils): 77.56 (1.97 mm)

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 7days at 23 Â± 2 Â°C

Mix ratio: 1A:1B by volume

Colors: Grey

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Re-coat dry time/temperature: 36 hours / 23 Â± 2 Â°C

Flushing or preparation instruction prior to use:

a) Flushing Time: General Flush
b) Estimate Flow Rate (gpm): 3
c) Temperature of Flush: 23 Â± 2 Â°C