



## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

Polycoat Products  
14722 Spring Avenue  
Santa Fe Springs, CA 90670-5108, United States

**Plant Location:**

Santa Fe Springs, CA, United States

**Standards:**

NSF/ANSI/CAN 61 - 2022

**Certificate:**

Issued Date: 09/21/2017

**Material/Product:**

Hot Cast Elastomer

**Contact Temperature:**

23 ± 2°C

**Models:**

Prepol PC 20-85

Maximum surface area in contact with water shall not exceed more than 1% of the total surface area.



## Material Characteristics:

Minimum pipe diameter (inches): 3.2

Maximum pipe surface area/volume ratio (sq in/L): 69.7

Maximum dry film thickness per coat (mils): 120

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Final cure time: 16 hrs

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes

Additional comments:

Maximum surface area in contact with water shall not exceed more than 1% of the total surface area.