



Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Tank Connection LLC
3609 N. 16th Street,
Parsons, KS 67357, United States

Plant Location:

Parsons, KS, USA

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 02/10/2022

Material/Product:

Bolted RTP Water tanks

Contact Temperature:

23 ± 2°C

Models:

H-Style #50 AZ63 Anode
RTP Bolted Steel Tank

Note:

1. The H-style#50 AZ63 Anodes are certified for use with tank connection certified RTP Bolted steel tanks only.
2. The AZZ Incorporated Hot Dip Galvanized Coating is certified for use with tank $\geq 20,000$ gallons.
3. The certified RTP Bolted steel tank is certified for use with uncoated 304/304L stainless steel tanks $\geq 4,035$ gallons, uncoated 316/316L stainless steel tanks $\geq 4,035$ gallons, uncoated 304/304L stainless steel pipes $\geq 3/4$ " nominal diameter, uncoated 316/316L stainless steel pipes $\geq 3/4$ " nominal diameter, uncoated EverTUFF Industrial PVC pipes, and uncoated Charlotte Pipe PVC pipes.
4. Aluminum Geodesic Domes and/or covers are non-wetted components and are installed above the liquid product zone in conformance with requirements.



Material Characteristics:

Minimum tank size (gallons): 4035

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Final cure time: 24 hours

Additional comments:

1. The H-style#50 AZ63 Anodes are certified for use with tank connection certified RTP Bolted steel tanks only.
2. The AZZ Incorporated Hot Dip Galvanized Coating is certified for use with tank $\geq 20,000$ gallons.
3. The certified RTP Bolted steel tank is certified for use with uncoated 304/304L stainless steel tanks $\geq 4,035$ gallons, uncoated 316/316L stainless steel tanks $\geq 4,035$ gallons, uncoated 304/304L stainless steel pipes $\geq 3/4$ " nominal diameter, uncoated 316/316L stainless steel pipes $\geq 3/4$ " nominal diameter, uncoated EverTUFF Industrial PVC pipes, and uncoated Charlotte Pipe PVC pipes.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.