



Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

VersaFlex Incorporated
686 S Adams Street
Kansas City, Kansas 66105, United States

Plant Location:

Kansas City, KS, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 04/16/2018

Material/Product:

Polyurea Interior/Lining Barrier System for Tanks, Vessels, Storage Containers that are used for Potable/Drinking Water.

Contact Temperature:

23 ± 2°C

Models:

AquaVers 405



Material Characteristics:

Minimum tank size (gallons): 600

Maximum tank surface area/volume ratio (sq in/L): 7

Maximum dry film thickness per coat (mils): 120

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 24 hours at 23 Â°C

Final cure time: 24 hours at 23 Â°C

Mix ratio: 1:1 by volume

Is this paint/coating system intended to be applied to a pipe? (Y/N): No



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.