



Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Polycoat Products
14722 Spring Avenue
Santa Fe Springs, CA 90670-5108, United States

Plant Location:

Bedford, TX, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 12/07/2021

Material/Product:

PC Grout VI LV System - Hydrophobic Polyurethane Water Cut-Off, Dual Component System VI LV

Contact Temperature:

23 ± 2°C

Models:

PC-Grout VI LV System

PC Grout VI LV is a drinking water system component in accordance with NSF/ANSI 61, Section 5 when properly mixed with PC Grout Catalyst.

PC Grout Catalyst is a drinking water system component in accordance with NSF/ANSI 61, Section 5 when properly mixed with PC Grout VI LV.



Material Characteristics:

Minimum tank size (gallons): 200,000

Maximum tank surface area/volume ratio (sq in/L): 1.2

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 5 min up to 24 hr at 77 Â± 5Â°F

Mix ratio: 10:1:1 by weight (PC-Grout VI LV:PC-Grout Catalyst:Water)

Colors: Original

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Maximum crack fill width (inch) on a normal run: 0.25

Flushing or preparation instruction prior to use: Normal flush for a minimum 15 seconds at approximately 3 gpm water at ambient temperature.

The wetted surface area of the product should not exceed more than 0.1% coverage of the total wetted surface area.