



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Diacom Corporation
5 Howe Drive
Amherst, NH 03031, United States

Plant Location:

Amherst, NH, United States

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 01/03/2019

Material/Product:

Peroxide Cured EPDM Diaphragm Compound

Contact Temperature:

23 ± 2°C

Models:

EC-6505-C

Certification for a maximum wetted surface area to volume ratio of 35 sq cm/L.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.