



Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

Conbraco Industries, Inc.
1418 S Pearl Street
Pageland, SC 29728, United States

Plant Location:

Pageland, SC, United States

Standards:

NSF/ANSI/CAN 61 - 2020
NSF/ANSI/CAN 61 - 2020
NSF/ANSI/CAN 61 - 2020
California Health & Safety Code §116875 [AB 1953 (2006)]
Vermont Act 193
Weighted average lead content $\leq 0.25\%$
Federal Public Law 111-380
Maryland Chapter 407, House Bill 372
Louisiana House Bill 471
NSF/ANSI/CAN 372 - 2020

Certificate:

Issued Date: 04/24/2013

Material/Product:

Reduced Pressure Principle Backflow Preventer (RPLF4A Series) 1/2"-2"

Contact Temperature:

82 \pm 2°C

Models:

RPLF4A 1" (4ALF205xx)
RPLF4A 1-1/2" (4ALF207xx)
RPLF4A 1-1/4" (4ALF206xx)
RPLF4A 1/2" (4ALF203xx)
RPLF4A 2" (4ALF208xx)
RPLF4A 3/4" (4ALF204xx)



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.