



## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

InstaCote, Inc.  
160 C Lavoy Road  
Erie, MI 48133

**Plant Location:**

Erie, MI, United States

**Standards:**

NSF/ANSI/CAN 61 - 2022

**Certificate:**

Issued Date: 06/07/2017

**Material/Product:**

Structural Polymeric Coating.

**Contact Temperature:**

80 ± 4°F

**Models:**

IC-202-2



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



## Material Characteristics:

Minimum tank size (gallons): 50,000

Maximum tank surface area/volume ratio (sq in/L): 1.66

Maximum dry film thickness per coat (mils): 270

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Refer to manufacturer instructions for details

Total cure time and temperature: 4 hrs at 75-80 °F

Mix ratio: 1:1 By Volume

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Flushing or preparation instruction prior to use:

Flush with adequate amount of water. Please refer to manufacturer's instruction.