



Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

Global EcoTechnologies, Inc.
2540 Verne Roberts Circle,
Antioch, CA 94509, United States

Plant Location:

Santa Fe Springs, CA, United States

Standards:

NSF/ANSI/CAN 61 - 2020

Certificate:

Issued Date: 05/15/2018

Material/Product:

Polyurethane Barrier Material

Contact Temperature:

23 ± 2°C

Models:

EF 1200 F
EF 1200 P
EF 1200 PW
EF 1200 PWF



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum tank size (gallons): 30,000

Maximum tank surface area/volume ratio (sq in/L): 1.8

Maximum dry film thickness per coat (mils): 500 (12.7 mm)

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 48 hrs at 23 ± 2 °C

Mix ratio: 2:1:6 by Volume (A:B:C)

Is this paint/coating system intended to be applied to a pipe? (Y/N): No



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.