



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Global EcoTechnologies, Inc.
2540 Verne Roberts Circle,
Antioch, CA 94509, United States

Plant Location:

Santa Fe Springs, CA, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 04/02/2019

Material/Product:

Endura-Flex 1988 - Polyureo Barrier Material.

Contact Temperature:

23 ± 2°C

Models:

Endura-Flex 1988 (black)
Endura-Flex 1988 (blue)
Endura-Flex 1988 (F-black)
Endura-Flex 1988 (F-blue)
Endura-Flex 1988 (F-off white)
Endura-Flex 1988 (F-red oxide)
Endura-Flex 1988 (off white)
Endura-Flex 1988 (red oxide)



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum tank size (gallons): 1500

Maximum tank surface area/volume ratio (sq in/L): 5

Maximum dry film thickness per coat (mils): 125

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 24 hrs at $23 \pm 2^\circ\text{C}$

Mix ratio: 1:2 by volume (A:B)

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Flushing or preparation instruction prior to use: Refer to Manufacturer's instruction for details.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.