



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Sika Corporation
201 Polito Ave
Lyndhurst, NJ 07071, United States

Plant Location:

Santa Fe Springs, CA, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 10/18/2021

Material/Product:

Potable Water Reservoirs, Tank Liners, Pond Liners, and Containment

Contact Temperature:

23 ± 2°C

Models:

Sikagard 7600 HG/VG



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.

ALS Group's Product Certification Listing directory contains the most current certified product(s) and supersedes all printed copies of the listings.



Material Characteristics:

Minimum tank size (gallons): 5000

Maximum tank surface area/volume ratio (sq in/L): 3.3

Maximum dry film thickness per coat (mils): 120 (3 mm)

Number of coats: 2

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 48 hrs at maximum of 23 Å°C

Mix ratio: 1:9 by Volume (A:B)

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

ALS



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.