



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Rhino Linings Corporation
9747 Businesspark Ave
San Diego, CA 92131, United States

Plant Location:

Greenville, TX, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 09/30/2021

Material/Product:

Spray Elastomer Coating

Contact Temperature:

23 ± 2°C

Models:

PipeLiner 5000 PW



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum pipe diameter (inches): 10

Maximum pipe surface area/volume ratio (sq in/L): 24.4

Minimum tank size (gallons): 20,000

Maximum tank surface area/volume ratio (sq in/L): 2.1

Maximum dry film thickness per coat (mils): 250

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Refer to manufacturer instructions for details

Total cure time and temperature: Full cure 72 hours at 75 Å°F

Shortest cure time between coats or layers: Immediate

Mix ratio: 1:1 (A:B) by weight

Colors: Light Blue, White

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): No

Additional comments:

Primer can be used for additional coating if adhesion to intermediate coat, top coat, and the substrate is required. Primer 1500 is applied at 3-5 wet mils and lining can be applied at 20 to 250 mils per pass.

Application includes pipe refurbishment.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.