



# ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

Rhino Linings Corporation  
9747 Businesspark Ave  
San Diego, CA 92131, United States

**Plant Location:**

San Diego, CA, United States

**Standards:**

NSF/ANSI/CAN 61 - 2022

**Certificate:**

Issued Date: 08/14/2018

**Material/Product:**

Rhino Lining Epoxy

**Contact Temperature:**

23 ± 2°C

**Models:**

Rhino Lining 1500 Waterborne Epoxy



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



## Material Characteristics:

Minimum pipe diameter (inches): 48

Maximum pipe surface area/volume ratio (sq in/L): 5.1

Minimum tank size (gallons): 4000

Maximum tank surface area/volume ratio (sq in/L): 3.6

Maximum dry film thickness per coat (mils): 10

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 24 hr @ 23Â°C

Final cure time: 24 hrs

Mix ratio: (4:1) Part A (resin) to part B (hardener) by volume

Colors: Opaque when mixed â€œ dries clear

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes

Additional comments:

Primer is applied at 3-5 wet mils