



# ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

Raven Lining Systems, Inc.  
686 S Adams Street  
Kansas City, KS 66105, United States

**Plant Location:**

Kansas City, KS, United States

**Standards:**

NSF/ANSI/CAN 61 - 2022

**Certificate:**

Issued Date: 01/30/2024

**Material/Product:**

Polyurethane Hybrid Coating

**Contact Temperature:**

23 ± 2°C

**Models:**

AquataFlex 505



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



## Material Characteristics:

Minimum pipe diameter (inches): 36

Maximum pipe surface area/volume ratio (sq in/L): 6.8

Minimum tank size (gallons): 900

Maximum tank surface area/volume ratio (sq in/L): 5.9

Maximum dry film thickness per coat (mils): 300

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Refer to manufacturer instructions for details

Final cure time: 24 Hours

Mix ratio: 1:3 (volume ratio)

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.