



Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Specialty Products, Inc.
2410 104th Street Ct. S
Suite D
Lakewood, WA 98499, United States

Plant Location:

Lakewood, WA, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 05/12/2017

Material/Product:

Two component monolithic coating used for potable water containment

Contact Temperature:

23 ± 2°C

Models:

Polyprime 100



Material Characteristics:

Minimum tank size (gallons): 3000

Maximum tank surface area/volume ratio (sq in/L): 4.0 (25.81 sq cm/L)

Maximum dry film thickness per coat (mils): 115

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 4 hours at max 75 °C / 80 °F

Mix ratio: Refer to manufacturer instructions for details

Is this paint/coating system intended to be applied to a pipe? (Y/N): No



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.