



# ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

## Certified Product Listing

**For:**

Drinking Water System Components - Health Effects

**Company:**

Polycoat Products  
14722 Spring Avenue  
Santa Fe Springs, CA 90670-5108, United States

**Plant Location:**

Santa Fe Springs, CA, United States

**Standards:**

NSF/ANSI/CAN 61 - 2022  
NSF/ANSI 372 - 2022

**Certificate:**

Issued Date: 08/26/2024

**Material/Product:**

Polyliner & Polyprime - Polyurethane Barrier Material

**Contact Temperature:**

23 ± 2°C

**Models:**

Polyliner 21-F  
Polyliner 3042F  
Polyprime 21  
Polyprime 3042



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



## Material Characteristics:

Minimum tank size (gallons): 30,000

Maximum tank surface area/volume ratio (sq in/L): 1.8

Maximum dry film thickness per coat (mils): 500 (12.7 mm)

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 48 hrs at  $23 \pm 2^\circ\text{C}$

Mix ratio: 2:1:6 by Volume (A:B:C)\*\*

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Flushing or preparation instruction prior to use:  
Please refer to manufacturer's instruction.

\*\* Mix Ratio:

2:1:6 by volume(A:B:C) ( For Polyliner 21-F & Polyliner 3042-F)

Mix Ratio:

2:1 by volume ( A: B) (For Polyprime 21 & Polyprime 3042)