



# ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

Polycoat Products  
14722 Spring Avenue  
Santa Fe Springs, CA 90670-5108, United States

**Plant Location:**

Santa Fe Springs, CA, United States

**Standards:**

NSF/ANSI/CAN 61 - 2022

**Certificate:**

Issued Date: 12/07/2021

**Material/Product:**

PC Grout VI LV System - Hydrophobic Polyurethane Water Cut-Off, Dual Component System VI LV

**Contact Temperature:**

23 ± 2°C

**Models:**

PC-Grout VI LV System

PC Grout VI LV is a drinking water system component in accordance with NSF/ANSI 61, Section 5 when properly mixed with PC Grout Catalyst.

PC Grout Catalyst is a drinking water system component in accordance with NSF/ANSI 61, Section 5 when properly mixed with PC Grout VI LV.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



## Material Characteristics:

Minimum tank size (gallons): 200,000

Maximum tank surface area/volume ratio (sq in/L): 1.2

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 5 min up to 24 hr at  $77 \pm 5^\circ\text{F}$

Mix ratio: 10:1:1 by weight (PC-Grout VI LV:PC-Grout Catalyst:Water)

Colors: Original

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Maximum crack fill width (inch) on a normal run: 0.25

Flushing or preparation instruction prior to use: Normal flush for a minimum 15 seconds at approximately 3 gpm water at ambient temperature.

The wetted surface area of the product should not exceed more than 0.1% coverage of the total wetted surface area.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.