



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

SealBoss Corporation
1669 E Wilshire Avenue
Santa Ana, CA 92705, United States

Plant Location:

Santa Fe Springs, CA, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 12/07/2021

Material/Product:

SealBoss 1510 WaterStop Foam

Contact Temperature:

23 ± 2°C

Models:

SealBoss 1510 WaterStop Foam

SealBoss 1510 WaterStop Foam is a drinking water system component in accordance with NSF/ANSI 61, Section 5 when properly mixed with SealBoss 15X Accelerator.

SealBoss 15X Accelerator is a drinking water system component in accordance with NSF/ANSI 61, Section 5 when properly mixed with SealBoss 1510 WaterStop Foam.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum tank size (gallons): 40,000

Maximum tank surface area/volume ratio (sq in/L): 1.7

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 5min at 77 Â± 5Â°F up to 24hr at 77 Â± 5Â°F

Mix ratio: 10:1:1 by weight (SealBoss 1510 WaterStop Foam : SealBoss 15X Accelerator : Water)

Colors: Original

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Maximum crack fill width (inch) on a normal run: 0.25

Flushing, preparation, or application instruction prior to use:

Normal flush for a minimum of 15 seconds at approximately 3 gpm water at ambient temperature.

The surface area of the product that touches water should not exceed more than 0.1% coverage of the total surface area.