



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

SealBoss Corporation
1669 E Wilshire Avenue
Santa Ana, CA 92705, United States

Plant Location:

Santa Fe Springs, CA, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 12/07/2021

Material/Product:

SealBoss 1510 WaterStopFoam F

Contact Temperature:

23 ± 2°C

Models:

SealBoss 1510 WaterStopFoam F

SealBoss 1510 WaterStopFoam F is a drinking water system component in accordance with NSF/ANSI 61, Section 5 when properly mixed with SealBoss 15X Accelerator.

SealBoss 15X Accelerator is a drinking water system component in accordance with NSF/ANSI 61, Section 5 when properly mixed with SealBoss 1510 WaterStopFoam F.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum tank size (gallons): 40,000

Maximum tank surface area/volume ratio (sq in/L): 1.7

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 5 min up to 24 hrs at $77 \pm 5^\circ\text{F}$

Mix ratio: 10:1:1 by weight (SealBoss 1510 WaterStopFoam F : SealBoss 15X Accelerator : Water)

Colors: Original

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Maximum crack fill width (inch) on a normal run: 0.25

Flushing or preparation instruction prior to use: Normal flush for a minimum 15 seconds at approximately 3 gpm water at ambient temperature.

The wetted surface area of the product should not exceed more than 0.1% coverage of the total wetted surface area.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.