



# ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

SealBoss Corporation  
1669 E Wilshire Avenue  
Santa Ana, CA 92705, United States

**Plant Location:**

Santa Fe Springs, CA, United States

**Standards:**

NSF/ANSI/CAN 61 - 2022

**Certificate:**

Issued Date: 12/07/2021

**Material/Product:**

SealBoss 1570 WaterStopFoam F

**Contact Temperature:**

23 ± 2°C

**Models:**

SealBoss 1570 WaterStopFoam F

SealBoss 1570 WaterStopFoam F is a drinking water system component in accordance with standard NSF/ANSI 61 Section 5 when properly mixed with SealBoss 15X Accelerator.

SealBoss 15X Accelerator is a drinking water system component in accordance with standard NSF/ANSI 61 Section 5 when properly mixed with SealBoss 1570 WaterStopFoam F.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



## Material Characteristics:

Minimum tank size (gallons): 200,000

Maximum tank surface area/volume ratio (sq in/L): 0.97

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 5 min / 77 Â± 5 Â°F up to 24 hr / 77 Â± 5 Â°F

Mix ratio: 10:1:1 by weight (SealBoss 1570: SealBoss 15X Accelerator : Water)

Colors: Original

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

The Surface area of the product that touches water should not exceed more than 1% coverage of the total surface area.

Maximum crack fill width on a normal run = 0.25 inches.

Flush for a minimum 15 seconds at approximately 3 gpm at ambient temperature.