



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Zurn Water, LLC - Wilkins
1747 Commerce Way
Paso Robles, CA 93446, United States

Plant Location:

Paso Robles, CA, United States

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 06/10/2016

Material/Product:

Water Pressure Reducing Valve (500XL)

Contact Temperature:

23 ± 2°C

Models:

500XL (Size 1/2" - 3")

OPTIONS: (Any combination of options may be used)

None â€" Single union FNPT tailpiece connection (1/2" â€" 2" only)

None â€" Integral FNPT X FNPT connection (2-1/2" â€" 3" only)

C â€" Single union FC (female copper sweat) tailpiece connection

CPVC â€" Single union female CPVC tailpiece connection (3/4" & 1" only)

HLR â€" High/Low range spring - 10 to 125 psi spring range, factory set at 50 psi

HR â€" High range spring - 75 to 125 psi spring range, factory set at 85 psi

HT â€" 180 °F max temperature

L â€" Model does not contain an integral by-pass check valve (3/4" â€" 2" only)

LPC â€" 140 °F max temperature and 10 to 35 psi spring range, factory set at 20 psi

LPV â€" 180 °F max temperature and 10 to 35 psi spring range, factory set at 20 psi

SC â€" Sealed cage bell housing with stainless steel adjustment bolt and lock nut

P â€" Cap tapped and plugged for gauge

YSBR â€" Model SXL lead-free bronze "Y" strainer attached on inlet (1/2" â€" 2" only)

FC â€" Body with flanged end connections (2" â€" 3" only)



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.

ALS Group's Product Certification Listing directory contains the most current certified product(s) and supersedes all printed copies of the listings.