



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Zurn Water, LLC - Wilkins
1747 Commerce Way
Paso Robles, CA 93446, United States

Plant Location:

Paso Robles, CA, United States

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 10/29/2019

Material/Product:

Water Pressure Reducing Valve (600XL, 625XL)

Contact Temperature:

23 ± 2°C

Models:

600XL (Size 1/2" - 2")
625XL (Size 3/4" - 1")

OPTIONS: (Any combination of options may be used)

None – Single union FNPT tailpiece connection
C – Single union FC (female copper sweat) tailpiece connection
CPVC – Single union female CPVC tailpiece connection (3/4" & 1" only)
HLR – High/Low range spring - 10 to 125 psi spring range, factory set at 50 psi
HR – High range spring - 75 to 125 psi spring range, factory set at 85 psi
HT – 180 °F max temperature
L – Model does not contain an integral by-pass check valve (3/4" & 2" only)
LPC – 140 °F max temperature and 10 to 35 psi spring range, factory set at 20 psi
LPV – 180 °F max temperature and 10 to 35 psi spring range, factory set at 20 psi
SC – Sealed cage bell housing with stainless steel adjustment bolt and lock nut
P – Cap tapped and plugged for gauge



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.