



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Zurn Water, LLC - Wilkins
1747 Commerce Way
Paso Robles, CA 93446, United States

Plant Location:

Paso Robles, CA, United States

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 03/26/2018

Material/Product:

Spill-Resistant Pressure Vacuum Breaker (460XL)

Contact Temperature:

23 ± 2°C

Models:

460XL (Size 3/8" - 1")

Note: The listed model is certified to use for drinking water at 23 °C only.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.