



Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

Zurn Wilkins
1747 Commerce Way
Paso Robles, CA 93446, United States

Plant Location:

Paso Robles, CA, United States

Standards:

NSF/ANSI/CAN 61 - 2020
NSF/ANSI/CAN 372 - 2020

Certificate:

Issued Date: 11/09/2017

Material/Product:

Reduced Pressure Principle Backflow Preventer (975XL2)
Double Check Valve Backflow Preventer (950XLT2)

Contact Temperature:

23 ± 2°C

Models:

950XLT2 (Size 3/4" - 2")
975XL2 (Size 1/4" - 2")

975XL2 (Size 1/4" - 2")

OPTIONS: (Any combination of options may be used)

None - standard ball valves and test cocks

L - Less shut-off valves

FT - Test cocks with integral male 45° flare SAE test fitting

MS - Integral relief valve monitor switch (3/4"-2")

BMS - Integral battery operated relief valve monitor switch (3/4"-2")

S - Includes model SXL strainer on inlet (3/4"-2")

V - Includes union swivel elbows (3/4"-1")

SE - Includes street elbows (3/4"-2")

950XLT2 (Size 3/4" - 2")

OPTIONS: (Any combination of options may be used)

None - standard ball valves and test cocks

L - Less shut-off valves

FT - Test cocks with integral male 45° flare SAE test fitting

S - Includes model SXL strainer on inlet



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.