



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Zurn Water, LLC - Wilkins
1747 Commerce Way
Paso Robles, CA 93446, United States

Plant Location:

Paso Robles, CA, United States

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 09/27/2023

Material/Product:

Reduced Pressure Principle Backflow Preventer (975XL2)
Double Check Valve Backflow Preventer (950XLT2)

Contact Temperature:

23 ± 2°C

Models:

950XLT2 (Size 3/4" â€" 2")
975XL2 (Size 1/4" â€" 2")

975XL2 (Size 1/4" â€" 2")

OPTIONS: (Any combination of options may be used)

None â€" standard ball valves and test cocks

L â€" Less shut-off valves

FT â€" Test cocks with integral male 45° flare SAE test fitting

S â€" Includes model SXL strainer on inlet (3/4"-2")

V â€" Includes union swivel elbows (3/4"-1")

SE â€" Includes street elbows (3/4"-2")

BFSS-Includes Model 49BRXLSST Butterfly Valves (1-1/4" - 2")

950XLT2 (Size 3/4" â€" 2")

OPTIONS: (Any combination of options may be used)

None â€" standard ball valves and test cocks

L â€" Less shut-off valves

FT â€" Test cocks with integral male 45° flare SAE test fitting

S â€" Includes model SXL strainer on inlet



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.