



Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Fu San Machinery Co. Ltd.
22 Lane 89 Sec 4
Chang-Mei Road
Ho-Mei Town, Chang Hua, Taiwan, Province of China

Plant Location:

Chang Hua, Taiwan R.O.C.

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 11/26/2019

Material/Product:

Full Port Ball Valves

Contact Temperature:

23 ± 2°C

Models:

F1361FP
F1361FPK
F1361FPLD
F1361FPLDSS
F1361FPSS
F1362FP
F1362FPK
F1362FPLD
F1362FPLDSS
F1362FPSS

This product is not suitable for use in the United States with potable water due to failure to meet NSF/ANSI 372 "Lead Free" requirement.