



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Metal Improvement Co. LLC
80 Route 4 East Suite 310
Paramus, NJ 07652, United States

Plant Location:

Peachtree City, GA, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 08/09/2018

Material/Product:

PTFE Dry Film Lubrication

Contact Temperature:

23 ± 2°C

Models:

EM 6226

ALS



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum pipe diameter (inches): 0.5

Maximum pipe surface area/volume ratio (sq in/L): 488

Minimum tank size (gallons): 5

Maximum tank surface area/volume ratio (sq in/L): 40.4

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Yes

(1) Type of coat: Thinner

(2) Number of additional coats: 1

Total cure time and temperature: 30 mins at 80 °C and 1 hr at 204 °C

Mix ratio: Refer to manufacturer instructions for details

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.