



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Henkel Corporation (dba GeoTree Solutions)
1 Henkel Way
Rocky Hill, CT 06067, United States

Plant Location:

Fresno, TX, United States

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 01/07/2025

Material/Product:

LOCTITE GeoSpray 61

Contact Temperature:

23 ± 2°C

Models:

Geopolymer mortar



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum pipe diameter (inches): 6

Maximum pipe surface area/volume ratio (sq in/L): 40.7

Minimum tank size (gallons): 300

Maximum tank surface area/volume ratio (sq in/L): 9

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 24 hours at $23 \pm 2^{\circ}\text{C}$

Final cure time: 7 day at $23 \pm 2^{\circ}\text{C}$

Mix ratio: Refer to manufacturer instructions for details

Colors: Refer to manufacturers instructions for details

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes

Additional comments:

6mm requires 30 min flush, 7mm and above does not require flushing.