



Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Polycoat Products
14722 Spring Avenue
Santa Fe Springs, CA 90670-5108, United States

Plant Location:

Bedford, TX, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 12/07/2021

Material/Product:

PC-220 - Concrete and Plywood Decks, and a Membrane in Pedestrian and Vehicular Deck System

Contact Temperature:

23 ± 2°C

Models:

PC-220



Material Characteristics:

Minimum tank size (gallons): 1500

Maximum tank surface area/volume ratio (sq in/L): 5.7

Maximum dry film thickness per coat (mils): 160 Mils

Number of coats: Minimum 2 passes

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 24 hrs at Max 60 °C

Mix ratio: Refer to manufacturer instructions for details

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Flushing, preparation, and application instruction prior to use:

Flush with adequate amount of water. Please refer to manufacturer's instruction.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.