



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Quadex, LLC
18150 Imperial Valley Drive
Houston, TX 77060, United States

Plant Location:

Sandy, UT, United States

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 11/19/2024

Material/Product:

Coatings

Contact Temperature:

23 ± 2°C

Models:

DC1000E
SE3000



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.

ALS Group's Product Certification Listing directory contains the most current certified product(s) and supersedes all printed copies of the listings.



Material Characteristics:

Minimum pipe diameter (inches): 4

Maximum pipe surface area/volume ratio (sq in/L): 61

Minimum tank size (gallons): 50

Maximum tank surface area/volume ratio (sq in/L): 16.8

Maximum dry film thickness per coat (mils): 125

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 4 days @ 70°F

Shortest cure time between coats or layers: 2 hours

Final cure time: 4 days @ 70°F

Mix ratio: 2:1

Colors: White

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): No

Additional comments:

Flushing or preparation instruction prior to use:

a) Flushing Time: General Flush at 15 Minutes

b) Temperature of Flush: 23 ± 2 °C