



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Alchatek, LLC
4508 Bibb Blvd
Suite B-5
Tucker, GA 30084, United States

Plant Location:

Tucker, GA, United States

Standards:

NSF/ANSI/CAN 61 - 2024
NSF/ANSI 372 - 2024

Certificate:

Issued Date: 07/16/2025

Material/Product:

AP Lift 430 - Two Component, Structural Polyurethane Foam

Contact Temperature:

23 ± 2°C

Models:

AP Lift 430

Maximum surface area in contact with water shall not exceed more than 10% of the total surface area.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum tank size (gallons): 500

Maximum tank surface area/volume ratio (sq in/L): 7.5

Maximum dry film thickness per coat (mils): 120

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 7 days at $23 \pm 2^{\circ}\text{C}$

Mix ratio: 1:1 by volume

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

ALS