



# ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

Tank Connection LLC  
3609 N. 16th Street,  
Parsons, KS 67357, United States

**Plant Location:**

Parsons, KS, USA

**Standards:**

NSF/ANSI/CAN 61 - 2022

**Certificate:**

Issued Date: 02/10/2022

**Material/Product:**

Bolted RTP Water tanks

**Contact Temperature:**

23 ± 2°C

**Models:**

H-Style #50 AZ63 Anode  
RTP Bolted Steel Tank

**Note:**

1. The H-style#50 AZ63 Anodes are certified for use with tank connection certified RTP Bolted steel tanks only.
2. The AZZ Incorporated Hot Dip Galvanized Coating is certified for use with tank  $\geq 20,000$  gallons.
3. The certified RTP Bolted steel tank is certified for use with uncoated 304/304L stainless steel tanks  $\geq 4,035$  gallons, uncoated 316/316L stainless steel tanks  $\geq 4,035$  gallons, uncoated 304/304L stainless steel pipes  $\geq 3/4"$  nominal diameter, uncoated 316/316L stainless steel pipes  $\geq 3/4"$  nominal diameter, uncoated EverTUFF Industrial PVC pipes, and uncoated Charlotte Pipe PVC pipes.
4. Aluminum Geodesic Domes and/or covers are non-wetted components and are installed above the liquid product zone in conformance with requirements.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



## Material Characteristics:

Minimum tank size (gallons): 4035

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Final cure time: 24 hours

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): No

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): No

Additional comments:

1. The H-style#50 AZ63 Anodes are certified for use with tank connection certified RTP Bolted steel tanks only.
2. The AZZ Incorporated Hot Dip Galvanized Coating is certified for use with tank  $\geq 20,000$  gallons.
3. The certified RTP Bolted steel tank is certified for use with uncoated 304/304L stainless steel tanks  $\geq 4,035$  gallons, uncoated 316/316L stainless steel tanks  $\geq 4,035$  gallons, uncoated 304/304L stainless steel pipes  $\geq 3/4$ " nominal diameter, uncoated 316/316L stainless steel pipes  $\geq 3/4$ " nominal diameter, uncoated EverTUFF Industrial PVC pipes, and uncoated Charlotte Pipe PVC pipes.