



Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Polycoat Products
14722 Spring Avenue
Santa Fe Springs, CA 90670-5108, United States

Plant Location:

Bedford, TX, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 12/07/2021

Material/Product:

PC Grout II System - Hydrophobic Polyurethane WaterStop Cut-Off, Dual Component System II

Contact Temperature:

23 ± 2°C

Models:

PC Grout II System

PC Grout II is a drinking water system component in accordance with NSF/ANSI 61, Section 5 when properly mixed with PC Grout II Catalyst.

PC Grout II Catalyst is a drinking water system component in accordance with NSF/ANSI 61, Section 5 when properly mixed with PC Grout II.



Material Characteristics:

Minimum tank size (gallons): 20,000

Maximum tank surface area/volume ratio (sq in/L): 2.1

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 5min at $77 \pm 5^\circ\text{F}$ up to 24hr at $77 \pm 5^\circ\text{F}$

Mix ratio: 10:1:1 by weight (PC Grout II : PC Grout Catalyst : Water)

Colors: Original

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Maximum crack fill width (inch) on a normal run: 0.25

Flushing, preparation, or application instruction prior to use:

Normal flush for a minimum of 15 seconds at approximately 3 gpm water at ambient temperature.

The surface area of the product that touches water should not exceed more than 0.1% coverage of the total surface area.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.