



## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

Polycoat Products  
14722 Spring Avenue  
Santa Fe Springs, CA 90670-5108, United States

**Plant Location:**

Bedford, TX, United States

**Standards:**

NSF/ANSI/CAN 61 - 2022

**Certificate:**

Issued Date: 12/07/2021

**Material/Product:**

PC Grout IV System - Hydrophobic Polyurethane WaterStop Cut-Off, Dual Component System IV

**Contact Temperature:**

23 ± 2°C

**Models:**

PC Grout IV System

PC Grout IV is a drinking water system component in accordance with NSF/ANSI 61, Section 5 when properly mixed with PC Grout Catalyst.

PC Grout Catalyst is a drinking water system component in accordance with NSF/ANSI 61, Section 5 when properly mixed with PC Grout IV.



## Material Characteristics:

Minimum tank size (gallons): 40,000

Maximum tank surface area/volume ratio (sq in/L): 1.7

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 5min at 77 Â± 5Â°F up to 24hr at 77 Â± 5Â°F

Mix ratio: 10:1:1 by weight (PC Grout IV : PC Grout Catalyst : Water)

Colors: Original

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Maximum crack fill width (inch) on a normal run: 0.25

Flushing, preparation, or application instruction prior to use:

Normal flush for a minimum of 15 seconds at approximately 3 gpm water at ambient temperature.

The surface area of the product that touches water should not exceed more than 0.1% coverage of the total surface area.