ALS Group USA, Corp.
3337 Michelson Drive, Suite CN750, Irvine, CA 92612

Certified Product Listing

For:
Drinking Water System Components – Health Effects

Company:
Polycoat Products
14722 Spring Avenue
Santa Fe Springs, CA 90670-5108, United States

Plant Location:
Santa Fe Springs, CA, United States

Standards:
NSF/ANSI/CAN 61 - 2022

Certificate:
Issued Date: 12/07/2021

Material/Product:
Pipe Pro Ultra - Spray applied Polyurethane Coating

Contact Temperature:
23 ± 2°C

Models:
Pipe Pro Ultra

Material Characteristics:

Minimum pipe diameter (inches): 4

Maximum pipe surface area/volume ratio (sq in/L): 61

Minimum tank size (gallons): 1000

Maximum tank surface area/volume ratio (sq in/L): 5.7

Maximum dry film thickness per coat (mils): 120

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 24 hours at 23 Â± 2 Â°C

Mix ratio: 1:1 Volume

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes
(1) Certified for use on a new pipe? (Y/N): Yes
(2) Certified for use on a pipe intended for immediate return to service? (Y/N): No