



## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

Nu Flow Technologies (2000) Inc.  
106 McMaster Ave.  
Ajax, Ontario L1S 2E7, Canada

**Plant Location:**

Ajax, Ontario, Canada

**Standards:**

NSF/ANSI/CAN 61 - 2022

**Certificate:**

Issued Date: 11/08/2018

**Material/Product:**

Rapid Setting Polymeric Lining

**Contact Temperature:**

23 ± 2°C

**Models:**

NF176



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



## Material Characteristics:

Minimum pipe diameter (inches): 0.5 in

Maximum pipe surface area/volume ratio (sq in/L): 488 (3148 sq cm/L)

Maximum dry film thickness per coat (mils): 20

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 4 hr @ 23Â°C

Final cure time: 4 hr

Mix ratio: 100:60 by weight

Colors: Grey

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): No

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes

Additional comments:

Wash at 23Â°C for 1hr after final cure as tested per manufacturer instructions.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.