



Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

SippTech LLC
565 W Douglas
Suite 204
Wichita, KS 67213, United States

Plant Location:

Riverside, MO, USA

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 11/06/2018

Material/Product:

Polymeric Coating

Contact Temperature:

23 ± 2°C

Models:

SippSteel- Rigid



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum pipe diameter (inches): 6

Maximum pipe surface area/volume ratio (sq in/L): 40.7

Maximum dry film thickness per coat (mils): 1000

Number of coats: Multiple

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Refer to manufacturer instructions for details

Final cure time: 24 hours at $23 \pm 2^\circ\text{C}$

Mix ratio: 1:1 by Volume

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.